

Translation

In any case, the german original shall prevail.

Deutsche Gesetzliche
Unfallversicherung



Fachausschuss Elektrotechnik

Fachausschuss Elektrotechnik
Gustav-Heinemann-Ufer 130

Prüf- und Zertifizierungsstelle
50968 Köln

AEG Power Solutions GmbH
Emil-Siepmann-Str. 32
59581 Warstein-Belecke

Your ref.:

Your correspondence dated:

Our ref. UB.010.17 Pl/wi
(please state):

Contact name: Wolfgang Pohl

Phone: +49 221 3778-6312

Fax: +49 221 3778-6322

E-Mail: pohl.wolfgang@bgetem.de

Date: 03.02.2010

Certificate of compliance 10006

Product: Automatic switching device (ENS)

Type: Protect PV

Intended use: The automatic disconnection device is used as a safety interface between the generator and the public low-voltage distribution net. It serves as a replacement for a disconnection switch which is accessible to the distribution net operator at all times.

The device is integral part of the PV-converters:
PV 10, PV 2000, PV 2800 und PV 4600

Testing performed in accordance with:

DIN V VDE V 0126-1-1 (2006-02) "Automatic disconnection device between a generator and the public low-voltage grid"

The safety concept of the product named above tested in the test report 2.04.00532.1.0 of 12. August 2008 by Arsenal, Vienna, complies with the safety-related specifications at the time of the issuance of the certificate for the mentioned intended use.

The validity of the certificate of compliance shall cease no later than:

31 December 2014

- Martin Mehlem -
Head of the testing and certification body